



City of Austin

PUBLIC WORKS DEPARTMENT

Engineering Services Division

505 Barton Springs Road, Suite 900, Austin, TX 78704

Phone (512) 974-7048

March 26, 2020

PROJECT: Onion Creek District Park Reclaimed Main Phase 2

CIP ID: 5267.068

SOLICITATION NO.: CLMC782

SUBJECT: Answers to Bidders' Questions as of the date of this letter, per 00020-IFB Article 2 BID DOCUMENTS and 00100-ITB Article 1.9 Further Information.

The following are answers to prospective Bidder's questions as received on the referenced project. These answers do not modify the Contract. Any modifications to the Contract will only be through formal Addendum.

Q-1: Are you requiring CLSM backfill for receiving and sending bore pits because the bore pits are shaded a different color like they require CLSM but there are not any notes?

A-1: CLSM is not required to backfill the bore pits. The bore pits are backfilled similar to an open-cut trench. Specification 510.3(25) governs backfilling.

Please note that any document revisions will only be issued as addenda through the Austin Finance Online System.